

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 3240-1574:181

Page 1 of 1

CATEGORY: Duct Smoke Detector Housing/Base

LISTEE: ADT Security Services, Inc., 695 Route 46 West, Suite 200, Fairfield, NJ, 07004-1561
Contact: Ron Dalton (310) 725-2972 FAX (310) 725-2942

DESIGN: Models DH300P-ADT, DH-300PL-ADT, DH-300RP-ADT, and DH-300RPL-ADT duct smoke detectors. Units consist of an enclosure, electrical components, sampling and exhaust tubes and listed photoelectric smoke detector sensor. Refer to listee's data sheet for detailed product description and operational considerations.

INSTALLATION: In accordance with listee's printed instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, air velocity rating, and UL label.

APPROVAL: Listed as a duct smoke detectors for use in HVAC systems having air velocities between 500 to 4000 ft/min. Suitable for use with separately listed compatible fire alarm control units. Refer to listee's Installation Instruction Manual for details.

NOTE: Formerly 3240-0085:197

XLF: 3240-0028:205

05-20-2004



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued:

JUNE 23, 2004

*Listing Expires **June 30, 2005***

Authorized By:

DIANE K. AREND, Senior Deputy
Program Manager